



**ADDENDUM #3**

March 5, 2026

This Addendum is issued prior to the *Tender Closing Date*, in accordance with the Tender Documents and shall be considered an integral part of the *Contract Documents*, read together with the *Drawings*, Specifications, and Addenda previously issued and with all subsequent Addenda.

**QUESTIONS**

- Q1. Will 25 mm IGB be accepted as an alternative material for pipe bedding, backfill, and road structure?**
- A1. Pipe bedding gradation shall follow MMCD 31 05 17 – Aggregates and Granular Materials, clause 2.7 Granular Pipe Bedding and Surround Material, type 1. 19mm minus shall be used for base course material.
- Q2. Can gradation charts be provided for the specified import materials?**
- A2. Standard gradations for materials can be found in MMCD Standard Specifications.

**END OF ADDENDUM #3**