



REQUEST FOR PROPOSALS (RFP) - 2603

PLAYGROUND INSTALLATIONS

ADDENDUM #1 August 13, 2026

The Central Coast Regional District (CCRD) provides the following additional information and responses to questions received from proponents regarding the Request for Proposals (RFP) for the Playground Installation project, issued August 6, 2026

- Attached: - Obstacle Pole conceptual drawing
 - Photo showing style of cement/wood bench
- Required pole material: Clean cedar pole, treat below ground base with wood preservative.
- Whether the 8 ft dimension refers to the total pole length or the height above finished grade; 8 ft refers to total length but can vary 7-9 ft
- Required pole spacing and arrangement; See drawing. Staggard spacing, roughly 1-1.5 ft apart
- Required embedment depth and footing requirements: No concrete required, 3 ft depth
- Specific design, safety, treatment or finishing requirements. Wood to be smooth to prevent splinters

We are open to design suggestions.

COMMUNICATIONS REGARDING THIS RFP

Enquiries from all Proponents regarding this RFP must be directed to:

Contact: Hans Granander

Email: hgranander@ccrd.ca or ops@ccrd.ca Telephone: 250-982-0081

Information obtained from any other source regarding this RFP is not official and should not be relied upon.

Obstacle Poles

10-12"
diam
cedar

4"-6"
step
blocks

5-6 ft

3 ft

- smooth wood finish, no splinters
- treat below ground portion with wood preservative
- conceptual drawing, open to suggestions



